

Original Article

AI-Assisted Fault Prediction and Adaptive Control in Networked Industrial Automation Systems

Subash Chandran

Independent Researcher, USA.

Received: 03-13-2026

Revised: 03-30-2026

Accepted: 04-09-2026

Published: 04-12-2026

ABSTRACT

Networked industrial automation systems play a vital role in manufacturing, intelligent production, and distributed process control in modern times. But the more complex the system is, the more problems there are, like degradation of the equipment, unexpected failures, communication delay, packet loss, and changing operating conditions. Traditional fault detection methods using fixed thresholds and rules might not be able to detect complex patterns of degradation or react to varying conditions. To overcome these challenges, the paper introduces a framework for Fault Prediction and Adaptive Control (AIFP-AC) using Artificial Intelligence (AI) with a combination of sensor analytics, temporal deep learning, probabilistic fault estimation and constrained control optimization. The framework performs equipment measurements and network telemetry processing to forecast potential faults, measure equipment health, and analyze communication quality. The adaptive controller modifies the operating parameters in this manner while respecting the actuator limits, process constraints and safety requirements based on these predictions. A supervisory safety mechanism verifies control actions and initiates fallback strategies if there is more uncertainty. The proposed framework is assessed with fault-prediction accuracy, control performance, communication robustness and equipment availability, for reliable, efficient and resilient industrial automation.

KEYWORDS

Adaptive Control, Artificial Intelligence, Condition Monitoring, Fault Diagnosis, Industrial Automation, Industrial Internet Of Things, Networked Control Systems, Predictive Maintenance, Temporal Deep Learning, And Fault-Tolerant Control.

1. INTRODUCTION

1.1. Background

As the Industrial Internet of Things (IIoT) technologies have evolved, industries now have the ability to collect high-frequency sensor data from industrial equipment, such as vibration, temperature, pressure, electrical current, rotational speed and actuator position. Combining these physical measurements with network parameters, like latency, packet loss, and availability of communication, gives a complete picture of the health and operational conditions of equipment. These data can be used by artificial intelligence (AI), machine learning, and deep-learning techniques to detect abnormal patterns, classify faults, predict equipment degradation, and facilitate predictive maintenance. But predicting a fault doesn't mean the industrial performance will be improved, as the predicted abnormalities need to be converted to actions that can be taken – and taken in time – which are appropriate for the situation. This encourages the fusion of fault prediction mechanism and adaptive control system in a single system. Intelligent controllers can use predicted probabilities of failure and estimates of equipment health to modify operating references, change allowed control parameters, rebalance workloads, or start more safe operating modes. This integration is designed to increase the reliability of the equipment, minimize unplanned downtime and increase the efficiency of the operation under predetermined safety requirements.

1.2. Problem Statement



Fig 1 -Problem Statement

1.2.1. Delayed Fault Recognition

Industrial monitoring systems may rely on known limits and deviations in the monitored equipment to determine if a problem is present. These methods might not catch faults until much of the performance has degraded. Thus, fault prediction becomes crucial for timely maintenance and to alert of any unforeseen equipment failure.

1.2.2. Limited Temporal Modelling

Sequential dependencies and progressive degradation in industrial sensor data could be hard to capture by traditional static classification models. Often, failure of complex equipment happens as a result of changes in operating parameters such as vibration, temperature, pressure, and more. Temporal deep-learning models can aid in the recognition of these changing patterns and to enhance early fault prediction.

1.2.3. Communication Uncertainty

Networked industrial automation systems suffer from packet loss, intermittence and jitter. This can lead to partial observation of the sensors, delayed command to the control and decreased control accuracy. Therefore, the quality of the communication has to be taken into account for estimating the health of the equipment and for choosing adaptive control actions.

1.2.4. Disconnected Decision Layers

Most predictive maintenance systems do not directly incorporate their results into real-time control decisions, but rather produce fault warnings. This separation hinders the proactive response that industrial systems can make to anticipated equipment degradation. Combining fault prediction and adaptive control allows equipment-health information to be used to inform corrective actions and operating adjustments.

1.2.5. Operational Constraints

Automated control adjustments should meet actuator specifications, product quality, equipment operating constraints and process safety. Free control actions can lead to instability, high mechanical stress or unwanted production variations. So there is a need for constrained optimization and independent safety validation to ensure that adaptive actions stay within acceptable operating limits.

1.2.6. Changing Operating Conditions

The workload, environmental conditions, production schedules and machine configurations vary in industrial systems. These changes may affect the typical behaviour of normal sensors and the ability of the prediction models that have been trained to generalise. Therefore, adaptive monitoring, confidence assessment and periodic model validation is a key to ensure reliable performance under varying operating conditions.

1.2.7. Overall Research Problem

The main research question is how to create an integrated framework of AI-based early fault prediction and constrained real-time control adaptation. The framework should take into account the health of the equipment, the reliability of the communication, the uncertainty of the model, and safety in operation. These challenges can be addressed in support of reliable, efficient and resilient networked industrial automation systems.

1.3. Research Objectives

The major goal of this research is to create an integrated AI-Assisted Fault Prediction and Adaptive Control (AIFP-AC) framework to enhance the reliability, efficiency and resilience of networked industrial automation systems. The goal of the study is to build a synchronized multivariate model of equipment health and communication-network performance, which combines measurements taken from physical equipment with quantities derived from the network, such as latency, jitter, and packet loss. It also aims at creating a temporal learning model to predict the

probability of failure in the future and the degradation patterns of the equipment from historical and current observations. Another major goal is to develop an adaptive control mechanism which is risk-aware and can trade off tracking error, energy usage, control effort and predicted equipment failure risk while meeting a set of operational constraints. The project will also seek to integrate supervision safety validation, trustworthiness assessment and backup control, to ensure that unsafe operating actions are avoided due to unsafe AI predictions. Lastly, the study aims to define an experimental evaluation methodology that is repeatable to compare the proposed framework to the conventional threshold-based monitoring, machine-learning based fault prediction, and prediction-assisted control approaches. These goals will provide a systematic basis for incorporating predictive maintenance intelligence into a safe, responsive and efficient industrial control operation.

2. LITERATURE SURVEY

2.1. Conventional Fault Detection and Condition Monitoring

Conventional fault detection methods use physical models of the system, residual analysis, and statistical process monitoring and pre-defined thresholds to detect abnormal behaviour of industrial equipment. While model-based techniques involve comparing real sensor readings to simulated system responses, statistical techniques look for discrepancies from past operating patterns. Though these approaches are simple to calculate and are interpretable, the results rely on the accuracy of the system model and the choice of threshold. This leaves the possibility of degradation under operating conditions, false alarms caused by interacting faults, and nonlinear degradation, which can decrease the accuracy of the fault detection. Communication delays, packet loss, and incomplete measurements with networked industrial automation add further complexity to fault identification. The limitations underline the importance of approaches for integrated monitoring that incorporate both physical process and communication-state information.

2.2. Machine Learning and Deep Learning for Predictive Maintenance

Based on historical sensor data, machine-learning techniques such as decision trees, support vector machines, random forests, and gradient boosting can be used to automatically classify an equipment's condition. Deep learning models, like long short term memory (LSTM) networks, gated recurrent units, and convolutional neural networks, can learn complex temporal relationships and nonlinear patterns that relate to equipment degradation. When the ratio of labelled fault data is low, the previously mentioned auto encoders and unsupervised learning methods prove to be helpful in detecting previously unseen abnormalities. These methods help in early fault prediction, detecting anomalies, and remaining useful life estimation. But they need to be capable of adapting to varying operating conditions, be computationally efficient, be generalized to apply to other models, and have good data quality. Thus, continuous performance evaluation and false-alarm reduction and prediction latency reduction are required for reliable deployment.

2.3. Adaptive Control and Fault-Tolerant Industrial Automation

Adaptive Control techniques are those which dynamically adjust the parameters or operating strategy of the controller to keep the system performance constant for varying operating conditions.

There are several well-established methods such as gain scheduling, self-tuning regulators, model reference adaptive control and model predictive control (MPC) which are effective in handling system uncertainties and operational disturbances. Fault-tolerant control is an extension of these capabilities, to compensate for component degradation, redistribute control actions, and transition equipment into safe operating modes when required. Other opportunities for optimization of control policies exist in complex, nonlinear industrial environments using reinforcement learning. However, there are safety constraints, stability requirements, and real-time constraints that learned control strategies must meet. Combining predictive fault knowledge with adaptive control may allow for proactive control action before the equipment degradation becomes an unacceptable fault.

2.4. Research Gap and Proposed Direction

In previous studies, predictive maintenance and communication-aware fault detection were studied independently from each other, while the coordinated implementation of these concepts is still a challenging problem. Predictive maintenance systems in the past were more of a risk assessment of equipment failure, with no direct control action applied, and conventional controllers were mostly based on closed-loop control based on the actual error detected. In addition, when considering the industrial deployment, operational technology security, model interpretability, computational overhead and deterministic control behaviour need to be taken into account. The proposed framework overcomes these shortcomings by incorporating temporal fault prediction, communication-aware state estimation, constrained control optimization and supervisory safety validation. The framework is designed to enhance fault prevention, operational reliability, and system resilience within networked industrial automation scenarios by integrating the use of predicted equipment health for control adaptation.

3. METHODOLOGY

3.1. Proposed System Architecture and Research Framework

The proposed AI-Assisted Fault Prediction and Adaptive Control (AIFP-AC) framework is designed to fit in all the data acquisition, pre-processing, AI-based fault prediction, adaptive control optimization and safety-supervised execution into a single framework. It continuously monitors physical sensor readings and communication-network parameters to detect if the operation is abnormal and foresee any equipment failures. The forecasted fault information is used by the controller to select the corrective action, while respecting predefined operational constraints. A supervisory safety layer verifies the actions prior to execution, providing reliable operation and fallback control in the event of abnormal conditions.

3.1.1. Industrial Data Acquisition

The industrial data-acquisition layer gathers data from sensors, actuators, programmable logic controllers (PLCs) and communication networks in real-time. Parameters that are important are vibration, temperature, pressure, electrical current, equipment position, network delay, jitter, and packet-loss rate. Such measurements give critical insights into equipment condition, operation and

communication reliability. The proposed framework can detect abnormal pattern using continuous data collection and provide a timely fault prediction.

3.1.2. Pre-processing and State Construction

At the pre-processing and state construction layer, the data from the industrial measurement is processed into a structured representation that is appropriate for analysis by AI. It does data quality tasks such as time synchronization, noise filtering, data normalization, feature extraction and missing data handling. Features that are relevant to the system state are aggregated, such as statistical variations, temporal trends, and communication indicators, to build a comprehensive representation of system state. This process helps to ensure that the values fed into the model are consistent and better reflects the true equipment fault from a normal variation in operation.

3.1.3. AI Fault Prediction

The AI based fault-prediction layer utilizes historical and real-time sequences of sensor data to estimate the likelihood of equipment failure and degradation trends. Temporal learning models recognize the relationship between sensor measurements and discover early warning patterns which potentially lead to component failure. The model also measures the confidence in the prediction, which reflects the confidence level of the equipment condition estimated by the model. These predictions can give advance warning of interventions for the prevention of faults, which can then be acted upon by an adaptive controller before they escalate into a serious operational failure.

3.1.4. Adaptive Control Optimization

The adaptive control optimization layer evaluates the estimated risk of a fault incident, the equipment-health assessment, and operating conditions to decide which control actions to take. Takes up control parameters, reference signals, and/or resource allocation plans based on system needs and pre-defined constraints. Performance parameters including stability, energy efficiency, tracking accuracy and protection of equipment are taken into account during the optimization process. The framework also includes predicted degradation that can be used to guide control decisions, which can lead to proactive fault mitigation actions, not just corrective ones.

3.1.5. Safety Validation and Execution

The safety-validation and execution layer checks if the chosen control actions are within operation limits, equipment protection requirements and preconfigured safety rules. Existing industrial control systems (such as PLCs) are used to transmit validated commands to carry out the necessary adjustments. When a proposed action is in conflict with a constraint or the AI prediction is no longer reliable, the supervisory mechanism rejects the action and triggers a fallback strategy that is preprogrammed. Event logging and continuous feedback have a further contribution to make to traceability, fault analysis and reliable industrial operation.

3.2. Temporal Fault Prediction and Health-State Estimation

The proposed temporal fault-prediction module uses a multivariate industrial sensor sequence analysis system, which is based on the Long Short-Term Memory (LSTM) network, to detect patterns related to equipment degradation. The model takes a series of normalized observations, which include physical measurements, operating conditions and communication-network indicators, within some time interval of the observations. The LSTM's recurrent structure can learn temporal patterns and nonlinear relationships, which can be useful for detecting early signs of equipment failures. The hidden representation is then passed to a classification layer, which computes the likelihood of a fault in a fixed prediction horizon in the future. This facilitates the system to separate so existing abnormal conditions from future failure cases. If there are enough degradation measurements or run-to-failure data, an extra regression output can be used to calculate equipment degradation or remaining useful life (RUL). RUL estimation, however, is only provided when sufficient training data exist for reliable lifetime prediction.




Fig 2 - Temporal Fault Prediction and Health-State Estimation

3.2.1. Training Objective

The LSTM model is optimized by minimising the difference between the model predicted fault probabilities and the actual fault labels, using the binary cross-entropy loss. If degradation or RUL information is available, then a regression loss is added to the training objective to improve the health-state estimation. Regularisation techniques are used to control for over fitting and for better generalisation in different operating conditions(s). Class weighting or appropriate sampling methods can be used to deal with class imbalance due to the limited number of failure samples in the industrial fault dataset. Training and validation sets are used to select hyper parameters for the model, and then the model is evaluated on a separate test set.

3.2.2. Confidence and Fault-Risk Estimation

The prediction module computes a normalized fault-risk score based on the predicted fault probability, equipment degradation and model uncertainty. Uncertainty estimation methods are used to identify potentially unreliable predictions and are appropriate for assessing prediction confidence. Confidence in the prediction is assessed by using appropriate uncertainty estimation methods that detect out-of-distribution predictions or ensemble disagreement. The resulting risk score can be used for prioritizing maintenance and controlling adaptively based on need for the application. The

weights assigned to it are determined based on the validation data and risk factors associated with the operation. Moreover, AI-based risk assessments are not intended to supplant existing safety mechanisms; even if a model lowers the risk score, any hazardous conditions should trigger the appropriate safety protocols.

3.3. Risk-Aware Adaptive Control and Optimization

Reduce production rates, redistribute workloads, or make maintenance requests within acceptable parameters. The control process takes into account the dynamics of the system, external disturbances and equipment degradation to operate the system at the required level of performance while limiting potential risks. A finite-horizon optimization algorithm considers the tracking accuracy, control effort, forecasted failure probability and impulsiveness of control inputs to determine appropriate control inputs. Physical state limits, actuator constraints, and control rate restrictions are added to assure that selected actions are within a pre-defined operating envelope. If a sufficiently accurate process model can be obtained, then model predictive control (MPC) can be used for this purpose, otherwise gain scheduling or bounded parameter adaptation could be used for systems with limited modelling ability.

3.3.1. Communication-Aware Adaptation

Communication-aware adaptation considers the latency, packet loss and communication availability in making control decisions. Incorporating sensor measurement delays and command interruptions may lead to reduced control accuracy and instabilities in networked industrial automation systems. The proposed framework adds communication quality indicators to the supervisory decision process to determine network quality issues. If the quality of communication is not acceptable for an application, the controller may limit adaptation, use an estimated state of the application locally, or pass on control of the application to a pre-designed local controller. These answers are chosen based on the dynamics of the process, the communication architecture and safety needs. The framework takes into account network conditions as well as equipment health, thereby enhancing the reliability of control decisions when the network conditions change.

3.3.2. Constrained Policy Adaptation

The confined policy adaption mechanism proposes candidate control actions based on the state of the process, predicted fault risk, model confidence and communication indicators. Before acting, each candidate action is checked for adherence to predefined actuator limits and other operational constraints. A projection-based optimization process can optimize an infeasible candidate action to the nearest feasible control input with respect to a desired weighting matrix. This strategy minimizes the number of control switches, and keeps the values of the inputs within their tolerable ranges. However, the success of the input constraints does not ensure stability or overall safety of the system in closed loop. Hence, the proposed framework incorporates stability assessment, independent safety validation and fallback control mechanisms along with constrained action selection, enabling the system to operate reliably in dynamic industrial environments.

3.4. Optimization Workflow, Safety Validation, and Execution

The optimization workflow suggested here is a continuous cycle of sensing, predicting, deciding, validating and acting to facilitate a reliable fault prediction and adaptive industrial control. The system first loads the validated AI model, the operating configuration, the control limits and the safety parameters necessary for execution. The current state of the system is then derived from real-time telemetry such as sensor measurements, controller states, equipment-health indicators and network statistics, which are then pre-processed. The temporal prediction module calculates the probability of fault, degradation information and the prediction confidence, and then provides these values to the adaptive control module. Candidate actions are evaluated by the controller using tracking accuracy, control effort, predicted fault risk, and operational constraints. The supervisory layer performs feasibility check of each action in accordance with predefined safety limits, restrictions of actuators, communication conditions, and requirements of model-confidence before the action is executed. The validated actions are passed to the industrial controller and the invalid and uncertain actions trigger an appropriate fallback strategy. After the execution, the system keeps log of operational results, control errors, communication quality and maintenance events to perform continuous assessment. The safety-validation mechanism independently ensures compliance with allowed operating ranges, actuator limits, control-rate limits and protection requirements that apply to the application. Any action that fails to abide by these conditions will be rejected before it reaches the execution layer. If the confidence in the prediction lowers, communication error occurs or abnormal operating conditions are sensed, then a pre-defined conservative operating mode is activated by the supervisory controller. Depending on the equipment and related hazards, fall-back manoeuvres may involve the change to a traditional local controller, slowing down the operation, keeping a validated reference and/or a controlled shutdown. These protective responses need to be defined and assured on a case by case basis and need to be confirmed before deployment.

4. RESULT AND DISCUSSION

4.1. Experimental Setup and Evaluation Metrics

A networked industrial process or a validated digital twin that can simulate realistic operating conditions with equipment degradation, sensor noise, and communication noise can be used to evaluate the proposed AI-Assisted Fault Prediction and Adaptive Control (AIFP-AC) framework. Some representative test scenarios are: Motor-Bearing Degradation, Abnormal Temperature Change, Actuator-Response Degradation, Intermittent Packet Loss, and Variable Network Latency. After the collected dataset is partitioned in the order of chronology or machine-wise partitioning to avoid the occurrence of data leakage and to check the generalization ability of the proposed model. It is compared with four set-ups: threshold-based monitoring with conventional feedback control; machine-learning-based fault prediction with conventional control; prediction-assisted adaptive control without a complete, communication-aware supervision; and the complete proposed AIFP-AC framework. Precision, recall, F1-score, false-alarm rate and prediction lead time are used to evaluate fault-prediction performance, while root mean square error (RMSE), settling time and constraint-violation frequency are used to evaluate control performance. The metrics used to measure operational effectiveness are equipment availability, unplanned downtime and energy

usage per unit of production. The F1 score is a combination of precision and recall to give a fair evaluation of fault classification, especially if the number of faults is not as high as it typically would be. Moreover, downtime reduction is measured by the difference between baseline downtime and the downtime measured using the proposed framework and expressed as percentage of the baseline downtime. Comparisons can be made on the basis of percentage to control error and energy use when same production needs are kept. The robustness of the framework needs to be assessed with respect to communication disturbances and equipment degradation levels and changed operating conditions. It is suggested that multiple experiments, and consistent evaluation methods and statistical comparisons be used to validate the results observed. Tactical improvements should not be reported until after simulation or physical testing, as no improvement can be substantiated by experimental measurement. This evaluation methodology is systematic and offers a basis to evaluate the accuracy of fault prediction, effectiveness of adaptive control, communication resilience and operational efficiency.

4.2. Percentage-Based Comparative Performance Analysis

Table 1: Percentage-Based Comparative Performance Analysis

Performance metric	Threshold monitoring	ML prediction only	Prediction-assisted control	Proposed AIFP-AC
Fault-detection F1-score (%)	72	84	88	92
Faults detected before failure (%)	48	68	76	85
Reduction in control error (%)	10	12	25	32
Reduction in unplanned downtime (%)	8	18	27	35
Reduction in energy consumption (%)	3	5	8	12
Validated actions within constraints (%)	94	95	97	99




Fig 3 - Percentage-Based Comparative Performance Analysis

4.2.1. Fault-Detection F1-Score (%)

The F1 score for the fault detection problem considers the trade-off between precision and recall for the four candidate architectures. Machine Learning Prediction is able to make a better classification because it can detect complex patterns in sensor data, while Threshold-based monitoring offers a baseline. Temporal analysis or integrated risk estimation can be used to obtain the better classification performance by means of prediction-assisted control and proposed AIFP-AC framework. These values of 72%, 84%, 88 and 92 are illustrative only and should be verified by experimental evaluation.

4.2.2. Faults Detected Before Failure (%)

This is a percentage figure that indicates the number of fault events that are detected early enough to allow for the possibility of preventive intervention. Abnormalities can be detected with threshold-based monitoring after operating parameters are outside of limits, but can be detected with predictive models prior to the degradation. Adding fault predictions to adaptive control could further enhance the practical application of early warnings. Illustrative values of 48%, 68%, 76% and 85% need to be validated with recorded fault events and well-defined prediction lead time.

4.2.3. Reduction in Control Error (%)

A control-error reduction measurement is the measure of improvement in the capability of the process to track the specified process behaviour. If the machine learning prediction does not impact the controller decision, then limited improvements can be expected; however if the prediction does impact the controller decision then the operating parameters can be adjusted based on the predicted equipment condition as in prediction-assisted adaptation. The proposed AIFP-AC framework also takes the quality of the communications and working constraints into account for choosing control actions. The illustrative reductions of 10%, 12%, 25% and 32% should be based on similar values obtained by experiment control-error.

4.2.4. Reduction in Unplanned Downtime (%)

Unplanned downtime reduction is the percentage of unexpected equipment interruptions that predictive maintenance and adaptive control reduce. The ability to identify faults early can help in scheduling maintenance and minimize the risk of major equipment failures. The proposed framework is designed to achieve this objective through the use of degradation prediction, risk aware control and supervisory safety mechanisms. The illustrative reductions of 8%, 18%, 27% and 35% should be confirmed by multiple tests or operational data, from the same base.

4.2.5. Reduction in Energy Consumption (%)

Energy-consumption reduction compares the energy consumption of the improved monitoring and adaptive control with the energy consumption of traditional monitoring and control for the same production tasks. While conventional monitoring can offer some opportunities for proactive energy optimisation, adaptive monitoring strategies can adapt operating parameters to meet equipment health and workload demands. The proposed framework also takes into account the

control effort and predicted degradation to make a suitable operating action decision. Illustrative reductions of 3%, 5%, 8%, and 12% must be verified by measuring the energy consumption under similar production conditions.

4.2.6. Validated Actions within Constraints (%)

This measurement is the percentage of candidate control actions that meet the given operational constraints during evaluation. The proposed framework can enhance constraint compliance via action screening, communication-aware supervision and fallback control. The values of 94%, 95%, 97% and 99% are only illustrative and do not imply safety of the system. To make any conclusions about industrial deployment, independent verification of constraint violations, closed-loop stability, and functional safety is required.

4.3. Discussion, Limitations, and Deployment Implications

AI-Assisted Fault Prediction and Adaptive Control (AIFP-AC) is a proposed framework for an integrated solution for coordinating early fault detection, equipment-health estimation, communication-aware monitoring, and adaptive industrial control. The main advantage is that it allows for the inclusion of the predicted degradation of the equipment in the control decisions before the process reaches a critical operating condition. The architecture is different than existing monitoring systems that send alarms or prediction-only models that warn of faults without changing controller operation, in that it allows a supervised controller to adapt operating references, control parameters, and operating rates based on the equipment's health. The combination of network latency, jitter, and packet-loss data can also serve to further differentiate communication-related disturbances from possible equipment abnormalities and limits adaptation when measurement quality is compromised. However, the success of the framework hinges on the accuracy of the sensors, suitability of training data, and calibration of the prediction and the availability of adequate accurate process models. Rare fault events, varying production patterns and machine-to-machine variability can cause distribution shifts, which can decrease the predictive performance. Also, complex temporal models can impose higher computational demands and inference time, especially if deployed on resource-constrained devices, such as devices deployed on the industrial edge. Bad predictions can also lead to unneeded operating limitations, maintenance actions or decreased production efficiency. Adopting AI in operational technology (OT) also raises new cyber security risks such as unauthorized changes to the models, tampered sensor data, or compromised communication channels. Thus, systematic validation is necessary before this can be put into practice, and should be done by ablation, repeated experiments, uncertainty analysis, confidence interval, and testing under different network conditions. The full control setup should also be analysed in regards to worst case execution time, closed-loop stability, actuator constraint satisfaction and compatibility with relevant industrial safety standards. If the simulated deployment, digital-twin testing, HIL experiments and supervised pilot operation are integrated and followed by a staged deployment, it is possible to detect potential weaknesses before the deployment process is implemented on a large scale. Independent safety interlocks, controlled model updates, secure communication, event logging, and rollback mechanisms are all crucial aspects of deployment that should be retained. Finally, the

proposed framework needs to be validated and confirmed by reproducible experimental evidence that it will lead to improved accuracy of fault predictions, performance of control, equipment availability and energy efficiency in comparison to traditional monitoring and feedback-control strategies.

5. CONCLUSION

This paper introduced an AI-Assisted Fault Prediction and Adaptive Control (AIFP-AC) approach to enhance the reliability, operational efficiency, and fault resilience of networked industrial automation systems. The suggested architecture can be summarized in a collection of four components: temporal fault prediction, equipment-health estimation, communication-aware state construction, and constrained control optimization with supervisory safety validation. The measurements of the sensors are initially synchronized, and network telemetry is used to form representative temporal features for intelligent analysis. An LSTM-based prediction module predicts the likelihood of future problems and, if appropriate training data is available, it assesses equipment degradation or remaining useful life. Predictions are collapsed with communication-quality indicators and model-confidence estimates to form a risk-aware depiction of the industrial process. The adaptive control module is able to use this information to maximize the tracking accuracy, control effort, operating risk, and smoothness of the control action, while meeting specific operational constraints. Additionally, communication-aware adaptation can limit potentially suboptimal control changes in the presence of higher network latency and packet loss, or measurement error. An independent supervisory safety mechanism validates candidate actions and triggers fallback strategies in case of unsafe conditions or unreliable predictions. The proposed framework preserves conventional control mechanisms and the safety interlocks traditionally used to ensure reliable industrial operation, as opposed to approaches that give unconstrained power to learned models. The evaluation methodology offers a structured approach for comparing threshold based monitoring, machine learning based fault prediction, prediction assisted adaptive control, and the full proposed architecture based on their respective metrics, including F1-score, early fault detection rate, control error, unplanned downtime, energy consumption and compliance with constraints. The results, however, are only based on percentages and are not necessarily the actual percentage increases that were measured in the lab; actual percentage increases must be measured and demonstrated with reproducible tests and statistically significant results. Future research will include validation of the framework with industrial datasets, digital twins, hardware-in-the-loop and networked control test beds. Model uncertainty, cross-machine generalization, explainable predictions, cyber security resilience, computational efficiency, and formal safety verification are other issues that need to be investigated. In summary, the proposed AIFP-AC framework provides the method to implement predictive maintenance intelligence in constrained adaptive control. It will only be as effective as it is rigorously tested, applied in the specific context and proven to be safe, and successfully integrated into the present day industrial control system.

REFERENCES

- [1] R. Isermann, "Model-based fault-detection and diagnosis—status and applications," *Annual Reviews in Control*, vol. 29, no. 1, pp. 71–85, 2005.
- [2] Syed, Y. (2023). Polyglot Persistence and Enterprise Data Migration: Architectures, Consistency, and Practice. *American International Journal of Computer Science and Technology*, 5(3), 61-66. <https://doi.org/10.63282/3117-5481/AIJCV5I3P106>
- [3] S. X. Ding, *Model-Based Fault Diagnosis Techniques: Design Schemes, Algorithms, and Tools*, 2nd ed. London, U.K.: Springer, 2013.
- [4] Virendra Jangid. (2024). *Real-Time Risk Aggregation Frameworks for Basel III Compliance*. *International Journal of Technology and Applied Science*, 15(8). <https://doi.org/10.71097/IJTAS.v15.i8.1338>
- [5] M. A. A. Shoukat Choudhury, S. L. Shah, and N. F. Thornhill, *Diagnosis of Process Nonlinearities and Valve Stiction: Data Driven Approaches*. Berlin, Germany: Springer, 2008.
- [6] Nangi, P. R., Obannagari, C. K. R. N., & Settapi, S. (2022). Enhanced Serverless Micro-Reactivity Model for High-Velocity Event Streams within Scalable Cloud-Native Architectures. *International Journal of Emerging Research in Engineering and Technology*, 3(3), 127-135.
- [7] A. K. S. Jardine, D. Lin, and D. Banjevic, "A review on machinery diagnostics and prognostics implementing condition-based maintenance," *Mechanical Systems and Signal Processing*, vol. 20, no. 7, pp. 1483–1510, 2006.
- [8] Syed, Y. (2025). Generative AI Integration and RAG-Based Enterprise Tooling: Architectures, Techniques, and Organizational Impact. *International Journal of Scientific Research in Science, Engineering and Technology*, 12(6), 600-606. DOI: <https://doi.org/10.32628/IJSRSET2613255>
- [9] Virendra Jangid. (2023). *AI-Driven Optimization of Regulatory Reporting Systems in Global Banking*. *International Journal of Science and Applied Technology*, 14(4). <https://www.ijst.org/papers/2023/4/11259.pdf>
- [10] T. P. Carvalho et al., "A systematic literature review of machine learning methods applied to predictive maintenance," *Computers & Industrial Engineering*, vol. 137, Art. no. 106024, 2019.
- [11] Hosahalli Seenappa, V. K. (2025). Next-generation intelligent multi-cloud enterprise networking: Integrating secure architecture, AI-optimized traffic engineering, and LLM-driven autonomous network operations. *International Journal of Leading Research Publication (IJLRP)*, 6(12), 1–11.
- [12] Nangi, P. R., & Settapi, S. (2023). A cloud-native serverless architecture for event-driven, low-latency, and AI-enabled distributed systems. *International Journal of Emerging Research in Engineering and Technology*, 4(4), 128-136.
- [13] Vasantha Kumar Hosahalli Seenappa. (2025). Predictive Configuration Governance for AI-Assisted Network Automation in Hyperscale MPLS/IP Backbone Networks. *International Journal of Intelligent Systems and Applications in Engineering*, 13(2s), 352–358. Retrieved from <https://ijisae.org/index.php/IJISAE/article/view/8534>
- [14] Mullapudi, P. N. (2025). Pricing optimization across domains: A comparative review. *International Journal of Emerging Research in Engineering and Technology*, 6(3), 16-33.
- [15] Tayal, C. (2024). Big Data Pipeline Optimisation for Electronic Health Records (EHR). *International Journal of Artificial Intelligence, Data Science, and Machine Learning*, 5(3), 121-127.
- [16] Nangi, P. R., Obannagari, C. K. R. N., & Settapi, S. (2022). Self-auditing deep learning pipelines for automated compliance validation with explainability, traceability, and regulatory assurance. *International Journal of Artificial Intelligence, Data Science, and Machine Learning*, 3(1), 133-142.
- [17] Syed, Y. (2024). DevSecOps and Enterprise-Scale CI/CD Pipeline Engineering: Governing Delivery Velocity, Embedded Security, and Release Automation Across Polyglot Environments. *International Journal of Scientific Research in Science, Engineering and Technology*, 11(5), 475-484. DOI: <https://doi.org/10.32628/IJSRSET2513156>
- [18] R. K. Mobley, *An Introduction to Predictive Maintenance*, 2nd ed. Burlington, MA, USA: Butterworth-Heinemann, 2002.
- [19] Casadei, A., Bhaduri, S., Malshe, R., Mullapudi, P., Ratan, R., Pole, A., & Rakshit, A. (2025). Scaling Causal Mediation for Complex Systems: A Framework for Root Cause Analysis. *arXiv preprint arXiv:2512.14764*.
- [20] S. Hochreiter and J. Schmidhuber, "Long short-term memory," *Neural Computation*, vol. 9, no. 8, pp. 1735–1780, 1997.
- [21] Tayal, C. (2026, January). Assessing the Scope of Optimising Operational Roles Through Intelligent Automation Frameworks. In *2026 IEEE 16th annual computing and communication workshop and conference (ccwc)* (pp. 0063–0068). IEEE.

- [22] Nangi, P. R., & Obannagari, R. N. CK, & Settipi, S.(2022). Predictive SQL Query Tuning Using Sequence Modeling of Query Plans for Performance Optimization. *International Journal of AI, BigData, Computational and Management Studies*, 3(2), 104-113.
- [23] F. A. Gers, J. Schmidhuber, and F. Cummins, "Learning to forget: Continual prediction with LSTM," *Neural Computation*, vol. 12, no. 10, pp. 2451-2471, 2000.
- [24] Mullapudi, P. N., Bhaduri, S., Casadei, A., Guo, L., Wang, H., Ashok, V., ... & Rakshit, A. (2025). An end-to-end Causal Modeling Framework for Advanced Attribution in Supply Chain Operations. In *KDD 2025 Workshop on AI for Supply Chain: Today and Future*.
- [25] Nangi, P. R. (2022). Multi-Cloud Resource Stability Forecasting Using Temporal Fusion Transformers. *International Journal of Artificial Intelligence, Data Science, and Machine Learning*, 3(3), 123-135.
- [26] Vasantha Kumar Hosahalli Seenappa. (2024). NG-iRTS: A Python and Ansible-Based Infrastructure as Code Framework for Enterprise Network Automation. *International Journal of Intelligent Systems and Applications in Engineering*, 12(23s), 4486-4492. Retrieved from <https://ijisae.org/index.php/IJISAE/article/view/8533>
- [27] Y. Syed, "Enterprise Observability and Software Delivery Performance: From Telemetry to Engineering Intelligence", *IJADSMC*, vol. 5, no. 2, pp. 01-08, Sep. 2022, doi: 10.67228/30713498/IJADSMC-2022PIIKP2M.
- [28] J. Lunze and J. H. Richter, "Reconfigurable fault-tolerant control: A tutorial introduction," *European Journal of Control*, vol. 14, no. 5, pp. 359-386, 2008.
- [29] Visweswaran, K. (2026, March). Low-Latency AI Models for Predictive Connection Management in Bluetooth Low Energy (BLE) Communication Systems. In *2026 6th International Conference on Expert Clouds and Applications (ICOECA)* (pp. 541-548). IEEE. <https://doi.org/10.1109/ICOECA68095.2026.11485045>
- [30] Paruchuri, J. K. (2024). *Apache Kyuubi on Kubernetes: Building Elastic Multi-Tenant Spark SQL Platforms*. INDO-CONTINENTAL ACADEMIC PUBLISHERS.
- [31] Reddy Nangi, P., & Reddy Nala Obannagari, C. K. (2023). Scalable End-to-End Encryption Management Using Quantum-Resistant Cryptographic Protocols for Cloud-Native Microservices Ecosystems. *International Journal of Emerging Trends in Computer Science and Information Technology*, 4(1), 142-153.
- [32] Seknametla, P. R., & Sunkara, R. (2025). Applying AIOps for Predictive Incident Management in DevOps-Driven Cloud Infrastructure. *International Journal*, 12(6).